



REQUEST FOR BIDS

Lower Elgin Road Bridge Repair Project

RFB No.: 18BCP09A

September 28, 2018

ADDENDUM #1

Notice to Respondents:

This addendum will be considered a part of Bastrop County's Request for Bids for the Lower Elgin Road Bridge Repair Project. Where provisions of this addendum differ from those of the original Request for Bids, this addendum will govern.

ACKNOWLEDGED

Printed Name of Respondent

Authorized Signature

Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED BID. FAILURE TO DO SO MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.

ITEMS FOR ADDENDUM 1

Q: What is the Engineers or County estimate too complete this project.

A: No estimate was established for this project.

Q: The specs do not mention re-painting of the bridge - please confirm that the bridge will not be re-painted.

A: Painting of the Bridge is NOT required.

Q: Does the 2" wood material get treated? Is there a spec for treating the 2" wood material?

A: The 2" wood will NOT be treated.

Q: Any welding or replacement of steel members - does this require a certified welded to complete this work?

A: Yes, welding will be required. Bastrop County requires a competent welder.

Q: Are any new steel members too be primed? Or left bear metal?

A: Steel Members are to be left as bare metal.

Q: What is the spec for the hardware to attach the wood planks to the steel structure?

A: Replace in-kind.

Q: Is a bid bond required for this project?

A: Page 34, II. Contract Terms and Conditions, Sub-section O (Bid, Payment and Performance Bonds) states that a 5% bid bond is due with the bid submission on October 1, 2018.

Q: Please confirm that performance and payment bonds will be required for this project.

A: Page 34, II. Contract Terms and Conditions, Sub-section O (Bid, Payment and Performance Bonds) states that the Contractor is responsible for submitting a (100% of contract amount) Performance and Payment bond to Bastrop County within 10 days of a Notice to Proceed.

Q: Is a special umbrella insurance policy required for this project?

A: Page 34, II. Contract Terms and Conditions, Sub-section R (Insurance) states the insurance requirements. A certificate of insurance showing that the contractor meets or exceeds the required limits and also showing Bastrop County as an additionally insured party must be presented to Bastrop County.