



REQUEST FOR BIDS

Precinct 2 Box Culvert Construction Project

RFB 24BCP10B

January 2, 2025

ADDENDUM #1

Notice to Respondents:

This addendum will be considered a part of Bastrop County's Request for Bids for Precinct 2 Box Culvert Construction Project. Where provisions of this addendum differ from those of the original Request for Bids, this addendum will govern.

ACKNOWLEDGED

Printed Name of Respondent

Authorized Signature

Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED BID. FAILURE TO DO SO, MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.

ITEMS FOR ADDENDUM #1:

Q: Is the length of the fence rail at the single box approximately 30' on each side plus the SKT ends?

A: Yes, see requested sketch.

Q: Is the length of the fence rail at the double boxes approximately 40' on each side plus the SKT ends?

A: Yes, see requested sketch.

Q: Can you please provide a plan view sketch of where the guard fence, DAT and SKT each begin and end at each structure? Please show the desired width between the face of rail.

A: See requested sketch.

Q: The box mounted posts are typically drilled and bolted through the top of the box culvert due to the need to align the base plate of the posts perfectly with the assembled rail. Please confirm this is acceptable.

A: This is acceptable.

Q: It is noted that the curb over the box is deleted. Are the top of the wing walls to be flush with the top of the box culverts?

A: Yes

Due to this addendum and the proximity of its release to the Christmas and New Years Holiday, Bastrop County is extending the due date of bids from January 8, 2025, until January 16, 2025. All bids are due to the Bastrop County Purchasing Department (1501 Business Park Drive, Bastrop, Texas 78602) no later than 2:00PM on January 16, 2025.

