



REQUEST FOR BIDS

**Precinct 2 Box Culvert Construction Project**

**RFB 24BCP12A**

January 6, 2025

**ADDENDUM #2**

Notice to Respondents:

This addendum will be considered a part of Bastrop County's Request for Bids for Precinct 2 Box Culvert Construction Project. Where provisions of this addendum differ from those of the original Request for Bids, this addendum will govern.

ACKNOWLEDGED

\_\_\_\_\_  
Printed Name of Respondent

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date

RETURN ONE COPY SIGNED COPY OF THIS ADDENDUM TO THE PURCHASING OFFICE WITH YOUR SEALED BID. FAILURE TO DO SO, MAY AUTOMATICALLY DISQUALIFY YOUR RESPONSE FROM CONSIDERATION FOR AWARD.

ITEMS FOR ADDENDUM #1:

Q: Does Bastrop County have any borrow areas for the common fill required? If possible any near each of the locations?

**A: NO**

---

Q: Will pit run base from the area pits suffice for the 8" crushed road topping?

**A: NO, the 8" Road Base material should be crushed limestone or re-cycled concrete.**

---

Q: Is it ok to use foreign reinforcement steel?

**A: NO**

---

Q: Can the construction start time be worked with to March 15 or April 1, 2025?

**A: Based upon the outcome of the bid process, the start date may be negotiated.**

---

Q: How long are the fill tapers expected for the approaches to each side of each box? The 10' length of the wings is not long enough to catch the depth of the fill likely desired. It's an approximation at best without road profiles provided.

**A: The remainder of the fill taper will slope to the shoulder of the road.**

---